

इंटरनेट

मानक

Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

“जानने का अधिकार, जीने का अधिकार”

Mazdoor Kisan Shakti Sangathan

“The Right to Information, The Right to Live”

“पुराने को छोड़ नये के तरफ”

Jawaharlal Nehru

“Step Out From the Old to the New”

IS 2132 (1986): Code of practice for thin-walled tube sampling of soils [CED 43: Soil and Foundation Engineering]



“ज्ञान से एक नये भारत का निर्माण”

Satyanarayan Gangaram Pitroda

“Invent a New India Using Knowledge”



“ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता है”

Bhartrhari—Nitiśatakam

“Knowledge is such a treasure which cannot be stolen”

BLANK PAGE



IS : 2132 - 1986

Indian Standard
CODE OF PRACTICE FOR
THIN-WALLED TUBE SAMPLING OF SOILS
(*Second Revision*)

UDC 624.131.365:006.76



© Copyright 1986

INDIAN STANDARDS INSTITUTION
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002

Indian Standard
CODE OF PRACTICE FOR
THIN-WALLED TUBE SAMPLING OF SOILS
(Second Revision)

Soil Engineering Sectional Committee, BDC 23

<i>Members</i>	<i>Representing</i>
ADDITIONAL DIRECTOR (GE)	Ministry of Railways (RDSO)
JOINT DIRECTOR (GE) (<i>Alternate</i>)	
DR ALAM SINGH	University of Jodhpur, Jodhpur
SHRI B. ANJIAH	Engineering Research Laboratories, Government of Andhra Pradesh, Hyderabad
DR R. K. BHANDARI	Central Building Research Institute (CSIR), Roorkee
SHRI S. K. KANSAL (<i>Alternate</i>)	
CHIEF ENGINEER (IPRI)	Irrigation Department, Government of Punjab, Chandigarh
DIRECTOR (DAM) (<i>Alternate</i>)	
DR T. N. CHOJER	Public Works Department, Government of Uttar Pradesh, Lucknow
DEPUTY DIRECTOR (R) (<i>Alternate</i>)	
SHRI A. VERGHESE CHUMMAR	F. S. Engineers Private Limited, Madras
SHRI C. S. DABKE	Howe (India) Private Limited, New Delhi
SHRI G. V. MURTHY (<i>Alternate</i>)	
SHRI A. G. DASTIDAR	In personal capacity (<i>5 Hungerford Court, 12/1, Hungerford Street, Calcutta</i>)
DIRECTOR (IRI)	Irrigation Department, Government of Uttar Pradesh, Roorkee
SHRI A. H. DIVANJI	Asia Foundations and Construction (Private) Limited, Bombay
SHRI A. N. JANGLE (<i>Alternate</i>)	
DIRECTOR	Central Soil and Materials Research Station, New Delhi
DEPUTY DIRECTOR (<i>Alternate</i>)	
SHRI N. V. DE-SOUSA	Cemindia Company Limited, Bombay
DR GOPAL RANJAN	University of Roorkee, Roorkee; and Institute of Engineers (India), Calcutta

(Continued on page 2)

© Copyright 1986

INDIAN STANDARDS INSTITUTION

This publication is protected under the *Indian Copyright Act* (XIV of 1957) and reproduction in whole or in part by any means except with written permission of the publisher shall be deemed to be an infringement of copyright under the said Act.

Indian Standard
CODE OF PRACTICE FOR
THIN-WALLED TUBE SAMPLING OF SOILS
(*Second Revision*)

0. FOREWORD

0.1 This Indian Standard (Second Revision) was adopted by the Indian Standards Institution on 30 January 1986, after the draft finalized by the Soil Engineering Sectional Committee had been approved by the Civil Engineering Division Council.

0.2 Undisturbed samples of soil are required for a number of soil test, such as unconfined compression test, consolidation test, permeability test and triaxial compression test. It has been recognized that it is not practicable to obtain a truly undisturbed sample but if certain procedures and precautions are observed it is possible to get relatively undisturbed samples which may be considered sufficient keeping in view the nature of tests to be performed on these samples. This code deals with the method of obtaining such samples using thin walled tube samplers with sampler heads (with and without check valves).

0.2.1 This standard was first published in 1963 and revised in 1972. In this revision, requirements regarding specifications for sampling tubes have been reviewed based on indigenous availability taking into consideration the general practice in the country, the sampling tubes have been restricted to four sizes only. The detail specification of sampling tubes and sampler head are covered in separate Indian Standard.

0.3 In very loose saturated sandy and silty, soils and clays the use of a piston sampler may often be necessary to secure a suitable undisturbed sample, the details of which are covered in IS : 10108-1982*.

0.4 For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS:2-1960†. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

*Code of practice for sampling of soils by thin wall sampler with stationary piston.

†Rules for rounding off numerical values (*revised*).

1. SCOPE

1.1 This Standard describes the method for obtaining relatively undisturbed cohesive and $C-\phi$ soil samples suitable for laboratory tests, using a thin-walled metal tube.

2. TERMINOLOGY

2.1 For the purpose of this standard, the definitions given in IS : 2809-1972* shall apply.

3. EQUIPMENT

3.1 Drilling Equipment — The equipment used shall provide a reasonably clean hole before insertion of the thin-walled tube, shall not disturb the soil to be sampled, and shall effect a rapid penetration of the tube into the soil to be sampled.

NOTE — Where casing is used, the equipment shall be capable of driving and removing the casing and shall include a pressure pump for clean-out operations. Where drilling fluid is used, a suitable mud pump is required. Where augers are used for clean-out purposes no special equipment other than that for sampling is generally required. The hole may be cleaned with a bailer with a flap valve but this should not be used in sandy soils.

3.2 Sampler Head — It shall conform to IS : 11594-1985†.

3.3 Thin-Walled Tubes — It shall conform to IS : 11594-1985†. These may be of Stainless Steel and Copper.

3.4 Sealing Material — Any wax that does not have appreciable shrinkage or does not permit evaporation of water from the sample shall be permitted. A mixture of paraffin wax and bees wax in the proportion 4 : 1 has also been found to be suitable.

3.5 Miscellaneous Items — Labels, data sheets shipping containers, etc.

4. PROCEDURE

4.1 Driving the Casing — Where casing is used it shall not be driven below the sampling level, and casing pipe should be in such a way that it does not disturb the soil to be sampled.

*Glossary of terms and symbols relating to soil engineering (*first revision*).

†Specification for mild steel thin walled sampling tubes and sampler heads.

4.2 Cleaning the Hole

4.2.1 The hole shall be cleaned to sampling elevation using whatever method is preferred that will ensure that the soil to be sampled is not disturbed. In saturated sandy and silty soils the drilling equipment should be withdrawn slowly to prevent loosening of the soil around the hole.

4.2.2 Where casing is used, the hole shall be cleaned out to the bottom or just below the casing. A clean-out auger should be used to clean the bottom of the hole, when necessary.

4.2.3 Bottom discharge bits shall not be permitted for clean-out purposes; side or upward discharge bits may be permitted.

4.2.4 The water level in the hole should be maintained at or above the ground water level, especially in soils that might be disturbed by the flow of ground water into the drill hole such as sandy and silty soils.

4.3 Obtaining Soil Sample

4.3.1 The depth of bottom of the casing, if used, below ground level and the water level in the bore hole should be noted.

4.3.2 Sampling shall be done as soon as possible after the clean-out operation and shall not be done after an interval, for example, where a hole has been cleaned-out and left overnight.

4.3.3 The assembled sampling tube should be lowered to the bottom of the hole, and the following information should be noted.

- a) Depth of bottom of bore hole below ground level;
- b) Amount of penetration of the sampling tube into the soil, under the combined weight of the tube and the rods; and
- c) Water level in the bore hole.

4.3.4 The sampling tube shall then be pushed into the soil by a continuous and rapid motion. In no case the tube shall be pushed farther than the length provided for the sample. About 50 mm shall be allowed for cuttings and sludge. A clearance of 10 to 20 mm shall be allowed below the sampled head in the tube. The depth of penetration of the tube shall also be noted. Before pulling out the tube, at least 5 min shall be allowed to elapse after pushing the tube after which the tube shall be turned at least for two revolutions to shear the sample off at the bottom.

NOTE — In case the equipment used for SPT is also used for driving the sampling tube, then the length of penetration shall be limited to 50 blows.

IS : 2132 - 1986

4.3.5 Samples shall be taken, by repeating the sampling procedures, at every change in stratum or at intervals not more than 1.5 m, whichever is less. Samples may be taken at lesser intervals if specified or found necessary. The intervals be increased to 3 m if in between vane shear test or SPT is performed.

4.3.6 Field Observations — Water-table information including ground water level, elevations at which the drilling water was lost, or deviations at which water under excess pressure was encountered should be recorded on the field logs.

4.4 Preparation for Shipment

4.4.1 Upon removal of the sampling tube, the length of the sample in the tube and the length between the top of the tube and the top of the sample in the tube shall be measured and recorded.

4.4.2 The disturbed material in the upper end of the tube shall be completely removed before applying wax for sealing. The length and type of the sample so removed should be recorded.

4.4.3 The soil at the lower end of the tube shall be reamed to a distance of about 20 mm. After cleaning both ends shall be sealed with wax applied in a way that will prevent wax from entering the sample. Wax used for sealing should not be heated to more than a few degrees above its melting temperature. The empty space in the samplers, if any, should be filled with moist soil, saw dust etc, and the ends covered with tight fitting caps.

4.4.4 If it becomes necessary to keep the samples at the site for some time, they shall be kept in the shade. They should be kept over a bed of sand, jute bags, saw dust, etc and covered over on top with similar material (sand, jute bags, saw dust, etc). The bed and top cover should be kept moist. Such bedding and top cover may also be provided at the time of shipment of the samplers with samples (*see 4.4.3*).

4.5 Labelling and Shipping

4.5.1 Labels giving the following information should be affixed to the tubes:

- a) Tube number,
- b) Job designation,
- c) Sample location,
- d) Boring number,
- e) Sample number,
- f) Depth,
- g) Penetration, and
- h) Gross recovery ratio.

- 4) Water level before insertion of casing if used
- 5) Water level after insertion of casing if used
- 6) Water level after pulling out of casing if used and possible
- 7) Whether drilling mud was used

d) Sampling Operations

- 1) Sampling tube No. 1 2 3 4 5 6 7 8
- 2) Sample No.
- 3) Method used for cleaning bottom of hole with date and time
- 4) Depth to bottom of casing below ground level
- 5) Date and time of sampling
- 6) Sampling details:
 - i) Total lengths, L_s
 - ii) Size
- 7) Level of water maintained in the bore hole
- 8) Depth to bottom of cleaned bore hole below GL
- 9) Level of water in the hole at the time of sampling
- 10) Amount of penetration of the tube under its weight and weight of rods
- 11) Method used for pushing the tube
- 12) Depth of penetration of the tube
- 13) Distance between top of tube and top of sample (measured after withdrawal), L_e
- 14) Whether soil sample in the tube was up to the cutting edge of the tube after withdrawal, if not how much within
- 15) Any evidence of slipping of the soil sample in the tube at the time of withdrawal
- 16) Thickness of soil sample removed from the cutting edge (bottom) end of the tube
- 17) Any disturbed material removed from the top end of the tube
- 18) Length of soil sample left in the tube

- 19) Weight of tube with soil sample left in the tube
- 20) Field description of soil, from soil removed from the ends of the tube (composition, condition, colour, structure, consistency, etc)
- 21) Remarks and special observations, if any

NOTE — This *pro forma* has been made comprehensive to include all observations indicated in the code. The Proforma may be modified to suit individual job conditions. Some of the items indicated in the *pro forma* may not be needed when sampling from a open trial pit. In such a case the direction of sampling, horizontal or vertical should also be indicated.

(Continued from page 2)

<i>Members</i>	<i>Representing</i>
ASSISTANT RESEARCH OFFICER (SRD)	Irrigation Department, Government of Uttar Pradesh, Roorkee
DEPUTY DIRECTOR RESEARCH (GE)-III	Ministry of Railways
ARE (GE)-II (Alternate)	
DIRECTOR (CS & MRS)	Central Soil and Material Research Station, New Delhi
DEPUTY DIRECTOR (CS & MRS) (Alternate)	
EXECUTIVE ENGINEER (DESIGNS) V	Central Public Works Department, New Delhi
EXECUTIVE ENGINEER (SMRD)	Public Works Department, Government of Tamil Nadu, Madras
EXECUTIVE ENGINEER (CD) (Alternate)	
DR K. K. GUPTA	Indian Institute of Technology, Delhi
DR J. M. KATE (Alternate)	
SHRI ASHOK K. JAIN	Ground Engineering Company Private Limited, New Delhi
SHRI VIJAY KUMAR JAIN (Alternate)	
SHRI S. K. MITRA	K. N. Dadina (Foundation Engineers), Calcutta
SHRI M. D. NAIR	Associated Instruments Manufacturers (India) Private Limited, New Delhi
PROF T. S. NAGARAJ (Alternate)	
SHRI T. K. NATARAJAN	Central Road Research Institute (CSIR), New Delhi
LT-COL K. M. S. SAHASI	Ministry of Defence (Engineer-in-Chief's Branch)
SHRI A. K. CHATURVEDI (Alternate)	
SHRI N. SIVAGURU	Ministry of Shipping and Transport, Roads Wing
SHRI M. K. MUKHERJEE (Alternate)	
SHRI S. K. SHOME	Geological Survey of India, Calcutta
SHRI P. N. MEHTA (Alternate)	



INDIAN STANDARDS INSTITUTION

Headquarters:

Manak Bhavan, 9 Bahadur Shah Zafar Marg, NEW DELHI 110002

Telephones: 3 31 01 31, 3 31 13 75

Telegrams: Manaksanstha
(Common to all Offices)

Regional Offices:

Telephones

*Western : Manakalaya, E9 MIDC, Marol, Andheri (East),
BOMBAY 400093 6 32 92 95

†Eastern : 1/14 C. I. T. Scheme VII M, V. I. P. Road,
Maniktola, CALCUTTA 700054 36 24 99

Northern : SCO 445-446, Sector 35-C,
CHANDIGARH 160036 { 2 18 43
3 16 41

Southern : C. I. T. Campus, MADRAS 600113 { 41 24 42
41 25 19
41 29 16

Branch Offices:

'Pushpak', Nurmohamed Shaikh Marg, Khanpur,
AHMADABAD 380001 { 2 63 48
2 63 49

'F' Block, Unity Bldg, Narasimharaja Square,
BANGALORE 560002 22 48 05

Gangotri Complex, 5th Floor, Bhadbhada Road, T. T. Nagar,
BHOPAL 462003 6 67 16

Plot No. 82/83, Lewis Road, BHUBANESHWAR 751002 5 36 27

53/5, Ward No. 29, R.G. Barua Road, 5th Byelane,
GUWAHATI 781003 —

5-8-56C L. N. Gupta Marg (Nampally Station Road),
HYDERABAD 500001 22 10 83

R14 Yudhister Marg, C Scheme, JAIPUR 302005 { 6 34 71
6 98 32

117/418 B Sarvodaya Nagar, KANPUR 208005 { 21 68 76
21 82 92

Patliputra Industrial Estate, PATNA 800013 6 23 05

Hantex Bldg (2nd Floor), Railway Station Road,
TRIVANDURM 695001 52 27

Inspection Office (With Sale Point):

Institution of Engineers (India) Building, 1332 Shivaji Nagar,
PUNE 411005 5 24 35

*Sales Office in Bombay is at Novelty Chambers, Grant Road,
Bombay 400007 89 65 28

†Sales Office in Calcutta is at 5 Chowringhee Approach, P. O. Princep
Street, Calcutta 700072 27 68 00